

WASH in depth Assessment to Al-Jable and Kerindang IDP camp

23rd -May 2021

Overview:

On 23rd of May 2021, WASH sector had conducted in depth assessment to AL Jabel and Kerindand IDP camp, participant had divided in two groups, G1 visited Al Jabal area, and G2 had visited Kerindand IDP CAMP.

Participants:

UNICEF, IOM, WR, IAS, TGH, PLRD, ECDO, UPO, HDPO, Spaces, MoH, and HAC.

Assessment Methodology:

- Focus group discussion with community.
- Key Informant Interview.
- Direct Observation.

WASH sector findings:



Key finding	Recommendation
Kerindang IDP camp	
<ul style="list-style-type: none">• People mainly fetching water from HAND PUMPS.• 50 hand pumps• 3 HPs are function• 47 HPs are none-function• Issue related to water is (waiting time at the source, lack of containers storage, and long distance)• Quantity of water delivered was decreased after the incident of Kerindang• All households have latrines, but a lot of them were damaged• Lack of Solid waste management• There are no partners working in ground• There is security concern around water source during night.• Lack of operation and maintenance of water supply and latrines, by community.	<ul style="list-style-type: none">• Repairing/rehabilitation of broken water sources• Provision of spare parts center.• Rehabilitation of damaged household latrines• Construction of communal emergency latrines.• Provision of cleaning tools• Re-activating of hygiene promoters
Al -Jabal area	
<ul style="list-style-type: none">• People mainly fetching water from Network, Hand pumps, unprotected wells, and donkey carts.• not all community have connected to water network due to some problems in transmission and distribution	<ul style="list-style-type: none">• Repairing/rehabilitation of broken water sources• Upgrade to some of hand pumps to mini water yards• Construction of communal emergency latrines.

WASH in depth Assessment to Al-Jable and Kerindang IDP camp

23rd -May 2021

<p>pipeline</p> <ul style="list-style-type: none"> • there are 13 hand pumps • one function HP • 12 none-function HPs • Issue related to the water (waiting time at water source, lack of containers storage, distance) • Quantity of water decreased after the incident. • Open wells have smell and ordure • People mainly defecated in household latrine, but a lot of them were damaged. • Solid waste management is very poor. • There are no partners working in the ground. • Unsafe to get water source at night due to security concern. • Lack of operation and maintenance of water supply and latrine , by community 	<ul style="list-style-type: none"> • Provision of cleaning tools. • Reactivating of hygiene promoters
---	---

Photos :

	
<p>- Focus group discussion with community. Kerindang</p>	<p>Damaged latrine</p>

WASH in depth Assessment to Al-Jable and Kerindang IDP camp

23rd -May 2021



Damaged latrine



Functioned HP - Kerindang



Damaged latrine



None-Function HP - Kerindang